

- Conduit must be either HDPE Type or at a minimum Schedule 40 PVC.
- Conduit must be buried a minimum of 12".
- Conduit runs should have a vault or "Pull Point" every 500 feet and/or at every third 90 or 45 degree bend.
- Conduits being installed by homeowners should have a pull string installed.
- Conduit size must be at least 2" in diameter or larger and should not contain more than (2) 90 degree and/or 45 degree bends. Anything over 250 feet should be at least 3" in diameter.
- The conduit should terminate outside the home so that we can ground the service properly.